



Product Service

CERTIFICATE

No. B 112244 0004 Rev. 00

Holder of Certificate: KunShan Misa Machinery Electrical Equipment Co.,Ltd

No. 888, Pengqing Road, Huaqiao Economic Development Zone
Kunshan City
215300 Kunshan City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Pressure switches

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

“

Test report no.: 874102128002-00

Valid until: 2026-11-10

Date, 2021-11-11

(Jie Zhu)

CERTIFICATE

No. B 112244 0004 Rev. 00

Model(s): SPC-100, SPC-101, SPC-102, SPC-103, SPC-106, SPC-106ML, SPC-110, SPC-116, SPC-120, SPC-130, SPC-130L, SPC-130ML, SPC-140, MS-P03

Parameters:

Rated voltage:	250VAC, 125VAC
Rated frequency:	50/60Hz
Rated current:	15(12)A for 125VAC, 8(12)A for 250VAC
Features of automatic action:	Type 1.B
Degree of protection:	IP44 (after mounted)
Ambient temperature limit of the switch head:	20T55
Degree of pollution:	2
Protection against electric shock:	Incorporated use, for class I appliance
Circuit disconnection:	Micro disconnection
Cycles of automatic action:	100 000cycles
Operating pressure:	Max. 4.0MPa (40bar)
PTI:	175V

Tested according to: EN 60730-1:2016/A1:2019
EN 60730-2-6:2016/A1:2020