



Product Service

CERTIFICATE

No. B 112244 0001 Rev. 00

Holder of Certificate: **KunShan Misa Machinery Electrical Equipment Co.,Ltd**
No. 888, Pengqing Road, Huaqiao Economic Development Zone
Kunshan City
215300 Kunshan City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Controllers**
Water flow switch

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 874102128001-00

Valid until: 2026-10-26

Date, 2021-10-27

(Jie Zhu)



CERTIFICATE

No. B 112244 0001 Rev. 00

Model(s): MS-01Bb,MS-01BS,MS-01D,MS-01E,MS-01,
HFS-25,HFS-25-S

Parameters:

Rated voltage: 250VAC, 125VAC
 Rated frequency: 50/60Hz
 Rated current: 3.5(3.5)A for 125VAC, 2.5(2.5)A for 250VAC
 Features of automatic action: Type 1.B
 Degree of protection: IP44
 Ambient temperature limit of the switch head: 20T55
 Degree of pollution: 2
 Protection against electric shock: Incorporated use, for class I appliance
 Cycles of automatic action: 100 000cycles
 Operating pressure: Max. 1MPa (10bar)
 PTI: 175V

Tested according to: EN 60730-1:2016/A1:2019
 EN IEC 60730-2-15:2019